

No.04(40)/FSR/CC/DFO/MNG/DK/2025

To

The Principal,
Bhuvana Jyothi Residential School,
Abhinandan Shirthady Village,
Moodabidri Taluk,
Dakshina Kannada District.

Sir,

Sub: Issue of Fire Safety Compliance Certificate with respect to fire prevention, fighting and evacuation measures maintained at Bhuvana Jyothi Residential School building constructed at Sy.No.136/P3 Shirthady Village, Moodabidri Taluk, Dakshina Kannada District.

Ref: 1) This Office Fire Safety Recommendation No.04/FSR/CC/DFO/MNG/DK/2021-25 Dated : 29-09-2025.
2) Your letter dated: 04-10-2025.
3) The Fire Station Officer Moodabidre report No.09(A)/CC/FSO/MFS/DK/2025 Dated:14-11-2025.

>>><<<

With reference to subject above cited, Fire Safety Recommendation was issued vide reference (1) to the premises of Bhuvana Jyothi Residential School building constructed at Sy.No.136/P3 Shirthady Village, Moodabidri Taluk, Dakshina Kannada District with a condition to fulfill the recommendations and compliance the same.

With reference cited (2) above, the Principal of Bhuvana Jyothi Residential School had requested for the issue of Fire Safety Compliance Certificate from our department. In this regard inspected the School building by Fire Station Officer Moodabidre on 13-11-2025 and has submitted his report on 14-11-2025. In his report, the Fire Station Officer Moodabidre has confirmed the compliance of fire fighting measures fully, that were communicated Fire Safety recommendation vide ref(1) with 07 employee's trained in 2 days fire prevention & fire fighting training at Regional Training Centre, kadri Fire Station Premises, Kuntikana, Mangaluru .

Under the above circumstances the Karnataka Fire & Emergency Services Department has issuing the Fire Safety Compliance Certificate to Bhuvana Jyothi Residential School building constructed at Sy.No.136/P3 Shirthady Village, Moodabidri Taluk, subject to proper maintenance of fire fighting installations in good working conditions.

This Fire Safety Compliance Certificate is valid up to 14-12-2027 for the period of two years and is renewable without fail.

U-DISE CODE-29240702004

Copy to:-

- 1) Copy submitted to the DGP & Director General, Karnataka Fire & Emergency Services, Bengaluru for information.
- 2) The Regional Officer, Central Board of Secondary Education, Bengaluru.
- 3) The Fire Station Officer, Moodabidre Taluk.



Yours faithfully,
District Fire Officer
Karnataka State Fire & Emergency Services
Mangalore, D.K.
15/12/25

No.04/FSR/DFO/MNG/DK/2021-25

Dated: 29 -09-2025

To

The Principal
Bhuvana Jyothi Residential School
Abhinandan Shirthady Village,
Moodabidri Taluk,
Dakshina Kannada District.

Sir,

Sub: Issue of Revised Fire Safety Recommendation to Bhuvana Jyothi Residential School building constructed at Sy.No.136/P3 Shirthady Village, Moodabidri Taluk, Dakshina Kannada District.

Ref:1) Standing order No.156-B(ತಿಳ್ಳಪಡಿ ಅದೇಶ) No.GBC(1)044/2020-21
Dated: 21-06-2022.

2) The Chief Fire Office, Fire Safety Recommendation No.19/Advice/CFO/MD/2017 dated: 30-11-2017.

3) The Chief Fire Office, Fire Safety Compliance report No.19/Advice/CFO/MD/2017 dated: 17-04-2021.

4) Your letter dated: 09-09-2025.

5) The Fire Station Officer, Moodabidri inspection report No.09/ Revised FSR/FSO/MFS/DK/2025 Dated:16-09-2025

<<<<>>>

With reference to the subject above cited Fire Safety Recommendation & renewal of Fire Safety Compliance report was issued vide ref.(2) & (3) ground floor & 03 upper floors to Bhuvana Jyothi Residential School building constructed at Sy.No.136/P3 Shirthady Village, Moodabidri Taluk, Dakshina Kannada District.

Now the applicant requested for revise Fire Safety Recommendation vide ref.(4). The School building was inspected by Fire Station officer Moodabidri on 16-09-2025 & with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under;

A. Details of the building / premises :-

01. Name and Address of the Applicant. : The Principal
Bhuvana Jyothi Residential School
Abhinandan Shirthady Village,
Moodabidri Taluk,
Dakshina Kannada District.

02. Name and Address of the premises. : Sy.No.136/P3
Shirthady Village,
Moodabidri Taluk,
Dakshina Kannada District.

03. Name and address of the Building owner : The Secretary
Bhuvana Jyothi Residential School
Abhinandan Shirthady Village,
Moodabidri Taluk,
Dakshina Kannada District

04. Number of buildings : One



05. Number of floors : Ground floor & 03 upper floors.

06. Floor-wise details of occupancy:-

Ground floor : 06 Class room, store room.

1st floor : 05 Class rooms

2nd floor : 02 Class room, computer lab, & 3 labs.

3rd floor : 03 halls

07. Height of the building : 14.00 mtrs

08. Site area : 14,690.09 Sq.mtrs (03.63 acres)

09. Built-up area of each floor:-

Ground floor : 498.70 Sq. mtrs.

1st floor : 498.70 Sq. mtrs

2nd floor : 498.70 Sq. mtrs

3r floor : 498.70 Sq. mtrs

10. Total built-up area : 1994.80 Sq.mtrs

11. Surrounding properties:-

East (Front) : Vacant land

West (Rear) : Vacant land

North (Side) : Vacant land

South (Side) : 04.00 mtrs wide internal road & Partly vacant land

12. open area available around the building :-

East (Front) : Minimum 06.00 mtrs available

West (Rear) : 04.00 mtrs


North (Side) : Minimum 06.00 mtrs available

South (Side) : Minimum 06.00 mtrs available

Allowed setbacks (open space) should be maintained free from further obstruction/construction

B. On inspection of this School/College premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the Premises	The Premises is abutting 04.00 mtrs. wide internal road which is connected to 09.00 mtrs wide Moodabidri –Hosmar road located on the Southern side. The both roads are hardened to carry the weight of 45,000 kgs.	-----




(1)	(2)	(3)	(4)
02. Number of entrances	One of 06.00 mtrs width	Complied	
03. Number of staircase	Nos. of staircases : Width of staircases Width of treads : Height of risers : Nos. of riser per flight : Height of handrails :	One 01.60 mtrs. 30 cms. 15 cms. 09 flight. 00.75 mtrs.	
04. Portable extinguishers	Provided in all 06 Nos. ABC Powder extinguisher each of 06 kgs. Capacity & 01 No's Co2 extinguisher of 4.5 kgs capacity . 02 No's, Co2 extinguisher each of 2 kgs capacity.	Thus the requirement Complied.	
05. Hose reel hose system	Provided One Hose Reel Hose near the staircase landing at each floor.	Thus the requirement Complied.	
06. At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Provided One terrace booster pump of 450 LPM or of 5HP capacity.	Thus the requirement Complied.	
07. Diesel generator	Provided One diesel generator of 45 kva capacity in the premises.	Thus the requirement Complied.	
08. Terrace tank	The hose reel hose system connected to an over head tank of 10,000 ltrs capacity.	Thus the requirement Complied.	
09. Escape routes	Direction in which the students have to move in the event of an emergency displayed in the corridor on each floor during evacuation .	Thus the requirement Complied.	
10. Fire order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency displayed along with the telephone number of Moodabidri Fire Station i.e. 08258-237021 and the telephone number of nearest ambulance service & Police station.	Thus the requirement Complied.	



11.	No smoking board	COTPA Sec-4 direction No Smoking area smoking here is an offence board written in English & Kannada both language displayed prominently at inside the entry / exit of the ground floor.	Thus the requirement Complied.
12	Fire Siren	A Fire Siren installed in the premises to inform the inmates in case of a fire emergency and evacuate the area at ground floor.	Thus the requirement Complied.
13	Nominate one Fire Nodal Officer	--	A fire nodal officer shall be nominated either from teaching or non teaching staff.
14.	Fire fighting training	07 employee's trained in 2 days fire prevention & fire fighting training at Regional training Centre Kadri Fire Station Premises, Kuntikana Mangaluru.	Not Complied At-least 40% of Teaching and non Teaching staff should be got trained in basic fire fighting at the Karnataka Fire and Emergency Services, Chief Fire officer's Office, Pandeshwara, Mangaluru – 575001 or at the R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore/ Regional Fire Officer, Range level with in 90 days from the date of issue of <u>Fire Safety Recommendation</u> .
15.	<u>Fire precautionary measures :-</u>	<p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustible waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should not be stored in the building.</p> <p>E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to out side.</p> <p>G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.</p>	

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Revised Fire safety recommendation' to Bhuvana Jyothi Residential School building constructed at Sy.No.136/P3 Shirthady Village, Moodabidri Taluk, Dakshina Kannada District, subject to condition and compliance of the above recommendations in column -4 of serial - B



within 3 months and compliance to the undersigned. The applicant has remitted Rs 5,500-00 (Rupees Five Thousand five hundred only) vide challan No.CR.0925007000498576 dated: 29-09-2025 at being the Advise fees.

This **Fire Safety Recommendation** is valid for only one year from the date of issue.

Yours faithfully,

[Signature]
District Fire Officer

Karnataka State Fire & Emergency Services
Mangalore, D.K.

29/09/25.

Copy to:-

- 1) Copy submitted to the DGP & Director General, Karnataka Fire & Emergency Services, Bengaluru for information.
- 2) The Regional Officer Central Board of Secondary Education, Bangalore.
- 3) The Fire Station Officer Moodabidre.

